



Certificate of Compliance

This certificate is issued for the following equipment:

Open Water-Spray Nozzles for Fire Protection

| Model | Nominal K-Factor (gpm/(psi) ^{1/2}) | Nominal Spray Angle (Degrees) | Nominal Thread Size (in.) | Finishes |
|-------|--|-------------------------------|---------------------------|--|
| AFF | 2.85 | 145 | 1/2 | Brass, Bronze, Stainless Steel, Titanium, and Cobalt, Copper, Nickel and Tantalum Based Alloys |

Prepared for: Bete Fog Nozzle Inc., 50 Greenfield St., Greenfield, MA 01301, USA

Manufacturing Location: Bete Fog Nozzle Inc., 50 Greenfield St., Greenfield, MA 01301, USA

FM Approvals Class: 2025

FM Approval Standard: Class Series 2021/2025 (February 2010)

Approval Identification: 3063752

Approval Granted: April 23, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller", written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group